

ACLARA 4 PORT DEMAND RESPONSE UNIT INFORMATION

POWER LIGHT (GREEN) <i>solid</i>	NORMAL <i>Unit has power and is operating properly.</i>
FAULT LIGHT (RED) <i>flashing or solid</i>	CONTACT COOPERATIVE <i>There is a problem with the unit's frequency or wiring.</i>
DEMAND LIGHT (YELLOW) <i>flashing</i>	NORMAL <i>One or more of the ports are under control.</i>



PROGRAM	POSSIBLE CONTROL DAYS	TIME EQUIPMENT IS OFF
Electric Heat	Once per month for billing and/or on the coldest days for peak demand.	Peak Hours
Cycled Air Conditioning	Once per month for billing and/or on the hottest days for peak demand.	Peak Hours (15 min. on/15 min. off)
Storage Heat	Every Day	6:00 a.m. - 10:00 p.m.
Stored Water	Monday - Friday	6:00 a.m. - 10:00 p.m. (Oct. - April) 9:00 a.m. - 10:00 p.m. (May - Sept.)
Peak Shave	When heat and air conditioning are controlled.	Peak Hours
ChargeWise	Every Day	7:00 a.m. - 11:00 p.m.

Cold Load Pickup Control:

Please note, there is a 15-minute Cold Load Pickup Control used to slowly bring energy loads back online after a control period. Your equipment could be controlled for up to 15 minutes after the control period ends to reduce a rush of energy back to the distribution network. Members are responsible for ensuring the demand response unit has power at all times.

